


"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



DELHI JAL BOARD, (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR, DELHI-110085.



**THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY**

Water sample collected from DJB stored water supply in the premises of Mata Sukhdevi Public School, Nangli Poona, Delhi - 36, Vide Challan no. - 243 dated 03.02.2022.

S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		S1
			Acceptable	Permissible	
1.	Date of collection	--	---	---	07.02.2022
2.	Date of Analysis	--	---	---	09.02.2022
3.	Colour	Hazen	5	15	Clear
4.	Odour	--	Agreeable		Agreeable
5.	Turbidity	N.T.U	1.0	5.0	0.98
6.	pH value	--	6.5 to 8.5	N.R.	7.4
7.	Electrical Conductivity	µmhos/cm	----	-----	278.6
8.	Total Dissolved Solid	(mg/l)	500	2000	181.09
CHEMICAL EXAMINATION					
9.	Phenolphthalein Alkalinity	(mg/l)	----	----	Nil
10.	Total Alkalinity	(mg/l)	200	600	70.0
11.	Total Hardness	(mg/l)	200	600	124.0
12.	Calcium Hardness	(mg/l)	200	600	84.4
13.	Magnesium Hardness	(mg/l)	200	600	39.6
14.	Calcium as Ca	(mg/l)	75	200	33.76
15.	Magnesium as mg	(mg/l)	30	100	9.50
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND*
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	ND*
18.	Nitrate (NO ₃)	(mg/l)	45	N.R.	3.35
19.	Sulphate (SO ₄)	(mg/l)	200	400	27.48
20.	Chloride (Cl)	(mg/l)	250	1000	13.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.02
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.27
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	*N.D.
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.75
BACTERIOLOGICAL EXAMINATION					
25.	Coli form per 100 ml at 37°C	MPN/100 mL	0		0

*N.D. - Not Detectable

Remarks: On the basis of tested parameters, water sample (S1) confirms to drinking water specification I.S.10500:2012 and may be used for drinking purpose.

Asstt. Chemist

Chemist/Bacteriologist

A.C.W.A. (HP- I)

C.W.A. (W&S)-II

